

GOVERNMENT OF ANDHRA PRADESH
A.P. STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

162
30/01/23
14/02

To:
The District Educational Officer,
Ananthapuram District.

Director General,
Disaster Response & Fire Services,
Andhra Pradesh, Vijayawada.

Rc.No.59/MSB/SR/ATP/2023, Dated: 07-02-2023.

A.P State Disaster Response & Fire Services Department - MSB Section - Eastern Region - Issuance of No Objection Certificate for Occupancy to the Existing Building of M/s. Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District- Regarding.

1. Application of M/s.Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District.
2. This Office Memo Rc.No.59/MSB/SR/ATP/2023, Dt:12-01-2023.
3. MSB Inspection Committee/Officer Report Rc.No.03/DDR&FO/STS/2023, Dt:18-01-2023.

<<0>>

The Management has requested for issuance of No Objection Certificate for occupancy to the Existing Building of M/s Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District in the reference 1st cited.

The Management has constructed the Building with Ground + (01) Upper Floor with a height of 07.24 Mtrs., with a total Built-up area of 4480.44 Sq.Mtrs., for Educational Occupancy. Previously, the management has not obtained Provisional No Objection Certificate from this Department and now applied for No Objection Certificate for Educational Occupancy.

The Multi Storied Building Inspection Committee/Officer has inspected the premises of M/s The Management has constructed the Building with Ground + (01) Upper Floor with a height of 07.24 Mtrs., with a total Built-up area of 4480.44 Sq.Mtrs., for Educational Occupancy on 17-01-2023, scrutinized the plans of above Existing Building and submitted the following report vide reference 3rd cited.

Particulars of the Building:

Name & Address of the Building	:	M/s. Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District.
Plot/Site Area	:	23244.53 Sq.Mtrs.,
Height of the Building	:	07.24 Mtrs.,
No. of Floors	:	Ground + (01) Upper Floor
Total Built-up Area	:	4480.44 Sq.Mtrs.,
Type of Occupancy	:	Educational Occupancy

Following are the Floor wise details of Existing Building total Built-up area.

Floor	Built-up area (In Sq.Mtrs.,)	Type of Occupancy (as per Clause 3.1 part-IV of NBC, 2016)
Ground	2240.22	Educational
First	2240.22	Educational
Total	4480.44	

(Contd....2p)

C. R. Reddy
Correspondent
Global E.M. School
LIC Colony, Near TV Tower
Ananthapuramu-515001

C. R. Reddy
Correspondent

The Management has provided the following Means of Escape.

Sl. No.	Details of Means of Escape	Minimum width required (as per clause 4.4 Part-IV of NBC, 2016)		As found in the inspection		Location	Deficit or Opinion of the Inspection Committee/ Officer
		No.'s	Width (in Mtrs.,)	No.'s	Width (in Mtrs.,)		
1.	Internal Staircase	01	01.50	01	01.20	Center west	Sufficient
				01	01.20	South-west	
2.	External Staircase	01	01.50	Nil	Nil		
Total:		02	03.00	02	02.40		

7) The details of Occupant Load per Unit and Exit Width required and provided are furnished as below:

Sl. No.	Floor	Built Up Area (In Sq.Mtrs.,)	No. of Occupants	Means of escape Required (as per clause 4.4 Part-IV of NBC-2016) in Mtrs.,	As found in the inspection (in Mtrs.,)	Deficit or Opinion of the Inspection Committee/ Officer
1.	Ground	2240.22	560	05.60	20.00	Sufficient
2.	First	2240.22	200	02.00	02.40	
Total		4480.44	760			

Further, we submit that, the Builder has provided the following Fire Fighting systems as per Table-07 of NBC, 2016.

Sl. No.	Fire Fighting Installations	Required	As found in the inspection	Deficit or Opinion of the Inspection Committee/ Officer
1.	Fire Extinguishers	30 No's	30 No's	Provided
2.	Hose Reel	04 No's	04 No's	Provided
3.	Terrace Water Tank	10,000 Ltrs.	20,000 Ltrs.	Provided
4.	Booster Pump	450 LPM	450 LPM	Provided
5.	Manual Operated Electric Fire Alarm System	NA	04 NO's	Provided

7 Electrical Safety:

Sl. No.	Description	Compliance
1	Whether Provided MCB's for each Floor ?	Yes
2	Whether provided Emergency lighting at Corridors/ Common passages and Staircases with UPS backup ?	NA

C. Mahes
Corresponder
Global E.M. Scl
LIC Colony, Near TV
Ananthapuramu-5

(Handwritten signature)

The Management has provided minimum Fire Safety measures as per Table-7 of IV of NBC-2016 and the Inspection Committee/Officer has tested the Fire safety equipments and found in working condition.

The Management is responsible all risks involved in case of Fire Accident.

In view of the above and based on the recommendation of the Inspection Committee/Officer, the No Objection Certificate for Occupancy is hereby issued to the Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District.

It is informed that, the Management of M/s Global English Medium School, No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District is requested to maintain the following conditions compulsorily for safety purpose.

No.	As Builder	As Occupant	As Security Personnel
	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
	Addition/alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
	This No objection Certificate for occupancy is only in fire safety point of view.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

C. Mahesh
 Correspondent
 Global E.M. School
 LIC Colony, Near TV Tower
 Ananthapuramu-515001

C. Mahesh
 Correspondent
 Glob

(Contd... 4p)

105 43 20

(26)

:: 4 ::

This No Objection Certificate for Occupancy is valid for a period of Five (05) years from the date of issue of this letter to the Management of M/s Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated.13-08-2021 and G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated.25-10-2021, two (02) months before expiry of this No Objection Certificate.

**Additional Director General of Police, C.I.D.,
(HFAC) Director General
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.**

Copy to the Management, M/s Global English Medium School, Sy.No:467-2, LIC Colony, Ananthapuram Rural, Ananthapuram District.

Copy to the Regional Fire Officer, Southern Region, Vijayawada.

Copy to the District Disaster Response & Fire Officer, Ananthapuram District.

**Correspondent
Global E.M. School
LIC Colony, Near TV Tower
Ananthapuramu-515**

II COUNTER SIGNED BY

Deputy Educational Officer
ANANTHAPURAM DIVISION
Ananthapuram District.

II COUNTER